Audit Date:	BAM-1020	_	al Number:	T212	Pette			
Flow Reference S	tandard Used:	Mode		Audits A G / Serial	No: 1410	294 Calibi	ration Date: 9	126/17
Temperature Sta	Mode	- VII	Serial			ration Date:	1-411	
	ure Standard Used	: Mode	el:	Serial	No:	Caliba	ration Date:	
Leak Check Valu	e: 8	s found:	0.9 lpm		as left:	0.6 lpm		
Ambient Temper	ature:	is found:	BAM -2.8 C	Ref. Std.	as left:	,	Ref. Std.	N/A
Barometric Press	_							
Flow Rate (Actua Flow Rate (EPA		is found:	slpm /	lpm slpm	as left: as left:	IL 7 Ipm /	14.41 lpm slpm	N/A N/A
			Mechai	nical Audits				
	00	ound 🔀	as left	PM1	0 particle trap		as left	N/A N/A
		ound ound	as left ×		M10 drip jar e 10 bug screen		as left as left	N/A N/A
		ound	as left		5 particle trap		as left	N/A
Rubber pinch		ound	as left		water-tight sea		as left	
Chassis ground v	vire installed: as f	ound 🔀	as left	Inlet tube per	pendicular to l	BAM: as found	as left _	
	Voltage Output A		N/A	-	Membrane A		Flow Contro	
DAC Test Screen	BAM Voltage Out		Voltage Input		ST m (mg):			BAM Flow
0.000 Volts 0.500 Volts		olts olts	Volts Volts		ABS (mg): ence (mg):		15.0 LPM 16.7 LPM	
1.000 Volts		olts	Volts		Difference:		18.4 LPM	
			Setup and C	alibration Va	lues			
Parameter (Date	Expected For		arameter	Expected	Found	Parameter	Expected	Found
Clock Time/Date RS232 baud			FLOW TYPE Cv			AP FRI		
STATION #			Qo			FRh		
RANGE			ABS			Password		
BAM SAMPLE			μ s\ v			Cycle Mode		
MET SAMPLE			K Factor			RH Control		
OFFSET			BKGD			RH Setpoint		
CONC UNITS COUNT TIME		- 12 M 92 Fee	STD TEMP HEATER	-		Datalog RH Delta-T Control		
FLOW RATE			el			Delta-T Setpoint	-	
CONC TYPE			Errors			Datalog Delta-T		
			st 6 Errors in	BAM-1020 E				
Err		Date	Time		Error		Date	Time
- / Park	nce	12/7/19	17:08	4	Penre		11/24/7	8135
150	6	11/24/17	6:35	6	Power		11/21/17	8:35
Audit Notes:	5-232 vyplu			7	Vonni	on ary	Val,	
	Yorksweve	Syncia		Downloa	als, w.	en que i ante	40Wh (0)	idea.